

## NOTES:

- 1. CONCRETE TO BE 3,000 PSI.
- 2. ENCASEMENT TO BE USED ONLY WHERE SPECIFIED ON PLANS.
- 3. PIPE SHALL BE DUCTILE IRON PIPE.
- 4. FILTER FABRIC TO BE PLACED UNDER RIP-RAP AND KEYED INTO EMBANKMENT.

